



FIXED OR ADJUSTABLE STRUCTURAL PIPE CAP WITH THREADED ROD - ALL CONNECTIONS PERMANENTLY WATERTIGHT

STRUCTURAL PIPE SUPPORT AND BASE PLATE - WELD PIPE TO BASE PLATE AND SECURE THROUGH DECK

ROOF REPAIR MEMBRANE - SPLICE TO EXISTING MEMBRANE

CONTINUOUS LAP SEALANT - TYP.

EXISTING PRECAST CONCRETE PAVERS

INFILL INSULATION SIZE AS REQUIRED TO RESULT IN FLUSH FINISH W/ TOP OF EXISTING ROOF

FIREPROOFING - RESTORE WHERE MISSING AND WHERE REQUIRED

STAINLESS STEEL STORM COLLAR w/ CLAMPING BAND SET IN CONTINUOUS BEAD OF GENERAL PURPOSE SEALANT - TOOL TO DRAIN

PRE-FORMED PIPE FLASHING WITH CLAMPING BAND - ADHERE TO MEMBRANE AND SEAL HORIZONTAL EDGE - PROVIDE WATER CUT-OFF MASTIC BETWEEN BOOT AND CONDUIT PENETRATION

THERMAL BARRIER - OMIT AT CONCRETE ROOF DECKS AND INSTALL STRUCTURAL PIPE SUPPORT DIRECTLY ONTO SURFACE OF CONCRETE

VAPOR BARRIER (2-PLY) - ADHERE TO EXISTING VAPOR BARRIER

CHANNEL SUPPORT AS REQUIRED TO ANCHOR EQUIPMENT ABOVE ROOF - REMOVE EXISTING FIREPROOFING AS REQUIRED TO SECURE DIRECTLY TO METAL DECK - REFERENCE STRUCTURAL

EXISTING FILTER FABRIC

COVER TAPE

EXISTING EPDM MEMBRANE - CLEAN & PRIME AT TIE-IN AREA

EXISTING INSULATION ASSEMBLY - REMOVE AT PENETRATION WITHOUT DAMAGING EXISTING VAPOR BARRIER

EXISTING VAPOR BARRIER

EXISTING THERMAL BARRIER OR CONCRETE

EXISTING METAL DECK

EXISTING FIREPROOFING

0732 EPDM FLASHING - STRUCTURAL PIPE SUPPORT (PREFORMED)  
SCALE: 3" = 1'-0"