



NOTE: EXISTING DUCT AND DAMPER MUST BE REMOVED AT EACH FLOOR LEVEL. REPLACE W/ 2 HR RATED HORIZONTAL ASSEMBLY & PIPE PENETRATION

0752 FLOOR PENETRATION MEZZANINE
 SCALE: 3" = 1'-0"