



GENERAL NOTES:

1. POSITION METER IN HORIZONTAL PLANE.
2. METER TO BE IN ACCESSIBLE LOCATION FOR READING, SERVICING, AND/OR TESTING. 4-6" A.F.F. PROVIDE LEAK TIGHT, PERMANENT SETTING TO ENSURE
3. METER CAN BE SERVICED WITHOUT NEGATIVELY AFFECTING KITCHEN PLUMBING.
4. PROVIDE PERMANENT ELECTRICAL GROUNDING TO PREVENT ACCIDENTAL SHOCK
5. PROVIDE HIGH QUALITY INLET SHUTOFF VALVE TO ALLOW METER MAINTENANCE. LOCATION OF METER MAY ALSO DICTATE A METER VALVE ON OUTLET SIDE TO PREVENT WATER DRAIN BACK WHEN METER IS REMOVED.

2203 WATER METER  
SCALE: NTS