



**NOTES:**

1. USE ROUND FLOOR SINK ASSEMBLIES. CORE DRILL FOR SLAB PENETRATIONS. CHIPPING, BUSH-HAMMERING OR JACK-HAMMERING OF CONCRETE FLOOR SLAB IS NOT ALLOWED.
2. FLOOR DRAINS AT OTHER FLOOR FINISHES AND SUB FLOORING SIMILAR.
3. NOT FOR USE WITH PVDF PIPE.
4. FLOOR SINK BODIES OR FLASHING COLLARS WITH SEEPAGE HOLES ARE NOT ALLOWED.

**KEY NOTE:**

- ① (2) LAYERS 3M E5A-4 ENDOTHERMAL MAT EXTEND DOWN PIPE MINIMUM 24". EXTEND ONTO CONCRETE DECK MINIMUM 2", SECURE THE ENDOTHERMAL MAT AT 10" ON CENTER AND 1" FROM EACH SEAM WITH STAINLESS STEEL BANDING. ALL SEAMS, BOTH LONGITUDINALLY AND CIRCUMFERENTIALLY, ARE TO BE TAPED WITH 3M T-49 TAPE.

2233 FLOOR SINK - CONCRETE FLOOR - METALLIC PIPE  
SCALE: NTS