

**EXPOSED AREAS** DRAIN ADHESIVE/ SEALANT

HYDROMENT ULTRA -SET BY BOSTIK, INC. - BUILD-UP IN 1/4" LIFTS TO FINAL DEPTH

NON-SHRINK GROUT

## **KEY NOTES:**

- (1) 3-5/8" x 0.038" METAL RUNNER (TYP)
- 3-5/8" x 0.019" CHANNEL (TYP)
- MINIMUM 1/4" THICKNESS CAULK EXTENDING MIN. 1/2" ONTO CONCRETE AND GYPSUM BOARD - 3M FIREDAM 150+ CAULK. (TYP) -SEE SECTION 078400, FIRESTOPPING.
- INTUMESCENT PIPE SLEEVE: 3M ULTRA PPD. SIZE TO MATCH PIPE, INSTALL PER MANUFACTURER'S RECOMMENDATIONS INSTALL ON A FLAT SURFACE ONLY USE **BOLTED CONNECTION - ONLY - INSTALL** BLOTS AT ALL BOLT CONNECTION POINTS. CONNECTION HARDWARE SHALL BE ALL STAINLESS STEEL 3/16" DIAMETER TOGGLE BOLTS WITH 1-1/4" DIAMETER FENDER WASHER - SEE SECTION 078400, FIRESTOPPING.
- (5) PROVIDE MINIMUM 1/2" BEAD CAULK AT INTERFACE WITH INUMESCENT SLEEVE PER SECTION 078400 FIRESTOPPING.

FLOOR SINK - CONCRETE FLOOR - PVDF PIPE

SCALE: NTS

HOLES IS NOT ALLOWED.