


MAINTAIN MINIMUM 24" SERVICE CLEARANCE IN FRONT OF SERVICE SIDE OF VACUUM PUMP AND 18" ON THE OTHER THREE SIDES.

2" SUCTION
2" EXHAUST




TOP VIEW


VACUUM PUMP (TYP)

VACUUM PUMP MOUNTING STAND

ANCHOR PLATE



FRONT VIEW



SIDE VIEW

2255

VACUUM WASTE PUMP ASSEMBLY

SCALE: NTS