



**NOTES:**

1. SEE SPECIFICATIONS FOR VIBRATION ISOLATION AND SEISMIC RESTRAINT.
2. PROVIDE THREE DUCT DIAMETERS OF STRAIGHT DUCT (MINIMUM 3') PRIOR TO FAN INLET. SLOPE DUCT TO EXHAUST FAN INLET.
3. SUPPORT ROOF MOUNTED DUCTWORK AND EXHAUST STACK PER SPECIFICATION SECTIONS 233113 AND 230529.
4. PROVIDE DISCONNECT AT FAN ON THE ROOF.
5. DUCT SUPPORT TO BE PROVIDED BY MECHANICAL CONTRACTOR.
6. PROVIDE APPROPRIATE ROOF CONNECTION DETAILS TO ACCOMMODATE ROOF MATERIAL TYPE AND CONSTRUCTION AT FAN LOCATION.