



KEY NOTES:

- ① CONICAL TAP AT LO-LOSS FITTING, AS SHOWN ON FLOOR PLANS.
- ② INLET DUCT MINIMUM LENGTH = 3'-0" OR 3X INLET DIAMETER; WHICHEVER IS LARGER. IF UNDER 10'-0" IN LENGTH, DUCT SIZE TO BE SAME SIZE AS TERMINAL UNIT INLET. IF LENGTH IS 10'-0" OR OVER, DUCT SIZE TO BE AS SHOWN ON PLAN.
- ③ HEATING COIL WHERE INDICATED. SEE PLANS FOR COIL CONNECTION ORIENTATION.
- ④ DISCHARGE DUCT TO BE 1" LINED SHEET METAL, MINIMUM 5'-0" LONG, SAME SIZE AS TERMINAL UNIT OUTLET, OR AS SHOWN ON PLAN, WHICHEVER IS LARGER. PROVIDE SOUND LINING AND SOUND TRAP AS INDICATED IN DRAWINGS AND SPECIFICATIONS.
- ⑤ TERMINAL UNIT.
- ⑥ ACTUATOR CONTROLLER, MOUNT CONTROLLER IN NEMA 1 ENCLOSURE.