



2-WAY VALVE

TYPICAL EXCEPT WHERE NOTED

BY-PASS VALVE

USE ONLY WHERE NOTED, AND AFTER LAST COIL ON PIPING RUN.

NOTES:

1. TYPICAL OF REHEAT COILS.
2. VARIABLE FLOW HWS/HWR SYSTEM.
3. CABINET UNIT HEATERS, UNIT HEATERS, AND FIN TUBE RADIATION, USE TWO POSITION MOTORIZED VALVES WITH FLOW LIMITING GRISWOLD TYPE FLOW CONTROL VALVE.

2344

TERMINAL UNIT - VARIABLE VOLUME REHEAT COIL PIPING

SCALE: NTS