

TERMINAL UNIT SCHEDULE

TAG NUMBER	LOCATION	SERVICE	TYPE	PRIMARY AIR						HYDRONIC COIL		MANUFACTURER & MODEL	NOTES
				INLET (IN)	MAX CFM	HEATING CFM	MIN CFM	LOW MIN CFM	MBH	GPM			
WR-X-2XX	XXX	XXX	VWR	XX	XXXX	XXX	XXX	XXX	XXX	XX.X	X.X	XXX	(X)
WR-X-2XX	XXX	XXX	VWR	XX	XXXX	XXX	XXX	XXX	XXX	XX.X	X.X	XXX	(X)
WR-X-2XX	XXX	XXX	VWR	XX	XXXX	XXX	XXX	XXX	XXX	XX.X	X.X	XXX	(X)
WR-X-XXX	XXX	XXX	VWR	XX	XXXX	XXX	XXX	XXX	XXX	XX.X	X.X	XXX	(X)
WR-X-XXX	XXX	XXX	VWR	XX	XXXX	XXX	XXX	XXX	XXX	XX.X	X.X	XXX	(X)

NOTES:

1. PRIMARY AIR TEMPERATURE 55°F (SUMMER), 65°F (WINTER). NOTE: CONCOURSE E EXTENSION PRIMARY SUPPLY AIR TEMPERATURE IS 60° F NOMINAL.
2. AIR PRESSURE DROP THROUGH TERMINAL UNIT TO BE NO GREATER THAN 0.25 IN.WG.
3. HYDRONIC HEATING COIL SIZED BASED ON 180°F ENTERING WATER TEMPERATURE AND 140°F LEAVING WATER TEMPERATURE.
4. HEATING COIL SIZED BASED ON A MINIMUM 75°F LEAVING AIR TEMPERATURE AT 55°F ENTERING AIR TEMPERATURE.

KEY NOTES:

- ① CO2 SENSOR LOCATED ADJACENT TO THERMOSTAT.
- ② OCCUPANCY SENSOR LOCATED WITHIN SPACE.
- ③ 2-WAY DELTA P CONTROL VALVE ON REHEAT COIL.
- ④ REBALANCE EXISTING TERMINAL UNIT.

KEY:

- VV = VARIABLE AIR VOLUME TERMINAL UNIT
- VWR = VARIABLE AIR VOLUME TERMINAL UNIT WITH REHEAT COIL
- FPS = FAN POWERED SERIES BOX
- FPP = FAN POWERED PARALLEL BOX