

EQUIPMENT NAMING CONVENTION:

E 4 L 1 T - 1A - A

POWER CLASSIFICATION: \_\_\_\_\_

- BLANK - NORMAL POWER
- E - EMERGENCY POWER
- S - LEGALLY REQUIRED / OPTIONAL STANDBY POWER
- U - UNINTERRUPTIBLE POWER

VOLTAGE: \_\_\_\_\_

- 2 - 208Y/120V
- 4 - 480Y/277V
- 5 - 4160Y/2400V
- 15 - 12470Y/7200V

EQUIPMENT: \_\_\_\_\_

- D - MAIN DISTRIBUTION PANEL
- S - SUB DISTRIBUTION PANEL
- B - BUSWAY
- M - MOTOR CONTROL CENTER
- A - AUTOMATIC TRANSFER SWITCH
- P - POWER PANEL
- L - LIGHTING PANEL
- T - TRANSFORMER
- C - CONTROLLER / STARTER
- U - UNINTERRUPTIBLE POWER SUPPLY

LEVEL: \_\_\_\_\_

- 0 - TUNNEL LEVEL
- 1 - DEPLANING LEVEL
- 2 - ENPLANING LEVEL
- 3 - MEZZANINE LEVEL
- 4 - ROOF

CONCOURSE/AREA: \_\_\_\_\_

- T - TERMINAL
- A - CONCOURSE A
- B - CONCOURSE B
- C - CONCOURSE C
- D - CONCOURSE D
- E - CONCOURSE E
- P - PARKING STRUCTURE
- U - CENTRAL UTILITY PLANT
- L - LONG TERM PARKING
- M - MAINTENANCE FACILITY
- R - ARFF
- X - EXIT PLAZA OFFICE

GRID LOCATION: \_\_\_\_\_

- 1A - NEAR INTERSECTION OF GRID LINES 1 AND A

IDENTIFIER: \_\_\_\_\_

- A - FIRST IN SERIES OF EQUIPMENT
- B - SECOND IN SERIES OF EQUIPMENT